



## Specifications

Item - 33743A

Model - LED WALL PACK ADJ 70W/4K

Bulb Type - LED

Input Voltage - 120-277

Watts - 70

Width - 9.75" (248 mm)

Length - 10.5" (267 mm)

Base - 7" (178 mm)

Color Temp - 4000K

CRI - 80

Lumen - 6700

Power Factor -  $\geq 0.9$

Finish - Black

Photocell - Yes

Dimmable - No

UL Rating - Suitable for Wet Locations

Life - 50,000

### Illuminance at a Distance

	Center Beam fc	Beam Width	
10.0 ft	30.2 fc	27.4 ft	30.1 ft
15.0 ft	13.4 fc	41.0 ft	45.1 ft
20.0 ft	7.6 fc	54.7 ft	60.2 ft
25.0 ft	4.8 fc	68.4 ft	75.2 ft
30.0 ft	3.4 fc	82.1 ft	90.3 ft

■ Vert. Spread: 107.7°  
■ Horiz. Spread: 112.8°

## Caution

- This fixture must be wired in accordance with the National Electrical Code and applicable local ordinance. Proper grounding is required to insure personal safety. Carefully observe grounding procedure under installation section.
- Make certain power is OFF before starting installation or attempting any maintenance. Risk of fire/electric shock. If not qualified, consult an electrician.
- Disconnect power at fuse or circuit breaker before installing or servicing
- Risk OF BURN--Disconnect power and allow fixture to cool before servicing.
- RISK OF PERSONAL INJURY--Fixture may become damaged and/or unstable if not installed properly. Tighten all fixture components to their recommended torque values.

## Precaución

- Este accesorio debe cablearse de acuerdo con el Código Eléctrico Nacional y la ordenanza local aplicable. Se requiere una conexión a tierra adecuada para garantizar la seguridad personal. Observe cuidadosamente el procedimiento de conexión a tierra en la sección de instalación.
- Asegúrese de que la energía esté APAGADA antes de comenzar la instalación o intentar realizar cualquier tipo de mantenimiento. Riesgo de incendio / descarga eléctrica. Si no está calificado, consulte a un electricista.
- Desconecte la energía en el fusible o disyuntor antes de instalación o mantenimiento
- Riesgo de QUEMADURAS: desconecte la alimentación y permita que el accesorio se enfríe antes de realizar el servicio.
- RIESGO DE LESIONES PERSONALES: el accesorio puede dañarse o inestarse si no se instala correctamente. Apriete todos los componentes del accesorio a sus valores de torque recomendados.

**⚠ WARNING**

- This fixture must be wired in accordance with the National Electrical Code and applicable local ordinance. Proper grounding is required to ensure personal safety. Carefully observe grounding procedure under installation section.
- RISK OF FIRE/ELECTRIC SHOCK-- Make certain to disconnect power at fuse or circuit breaker before installing or servicing.
- RISK OF BURN--Disconnect power. Allow fixture to cool before servicing.
- RISK OF PERSONAL INJURY--Fixture may become damaged and/or unstable if not installed properly.
- The mounting location should have enough strength to support the weight of the fixture.

Installation

1. If there is an existing fixture, remove it.
2. Loosen both outer side screws and open the housing, then loosen both inner side screws.
3. Expose the supply wires for the J-Box. Mount the mounting box to the J-Box with the supplied screws.
4. Gently pull the supply wires through the hole in the back housing.
5. Connect the black supply wire to the black fixture wire. Secure with the supplied wire nuts.
6. Connect the white supply wire to the white fixture wire. Secure with the supplied wire nuts.
7. Either wrap the green wire around one of the protruding screws or connect it to the supply ground wire.
8. Secure all wires with electrical tape (not supplied). Tuck all wires into the mounting box.
9. Tighten the inner side screws, close the housing, then tighten the outer side screws.

**⚠ ADVERTENCIA**

- Este accesorio debe cablearse de acuerdo con el Código Eléctrico Nacional y la ordenanza local aplicable. Se requiere una conexión a tierra adecuada para garantizar la seguridad personal. Observe cuidadosamente el procedimiento de conexión a tierra en la sección de instalación.
- RIESGO DE INCENDIO / DESCARGA ELÉCTRICA: asegúrese de desconectar la alimentación en el fusible o el disyuntor antes de realizar la instalación o el servicio.
- RIESGO DE QUEMADURAS - Desconecte la alimentación. Permita que el accesorio se enfríe antes de realizar el servicio.
- RIESGO DE LESIONES PERSONALES: el accesorio puede dañarse o inestarse si no se instala correctamente.
- La ubicación de montaje debe tener la resistencia suficiente para soportar el peso del accesorio.

Instalación

1. Si hay un accesorio existente, quítelo.
2. Afloje los dos tornillos laterales externos y abra la carcasa, luego afloje los dos tornillos laterales internos.
3. Exponer los cables de potencia de la caja de conexiones. Monte la caja de montaje en la caja de conexiones con los tornillos provistos.
4. Tire suavemente de los cables de alimentación a través del orificio en la carcasa posterior.
5. Conecte el cable de alimentación negro al cable negro / del accesorio. Fije con las tuercas de cable suministradas.
6. Conecte el cable blanco / del accesorio. Fije con las tuercas de cable suministradas.
7. Envuelva el cable verde alrededor de uno de los tornillos sobresalientes o conéctelo al cable de tierra.
8. Asegure todos los cables con cinta aislante (no incluida). Ponga todos los cables en la caja de montaje.
9. Apriete los tornillos laterales internos, cierre la caja y luego apriete los tornillos laterales externos.

