



Roadway Summary

noud nay building		
Cutoff Classification:	C	UTOFF
Distribution:	TYPE1,	SHORT
Max Cd, 90 Deg Vert:		9.0
Max Cd, 80 to <90 Deg:		201.9
Lumen	s % Lamp	
Downward Street Side:	2,198.4	35.2%
Downward House Side:	4,035.9	64.7%
Downward Total:	6,234.3	99.9%
Upward Street Side:	3.3	0.1%
Upward House Side:	3.1	0.1%
Upward Total:	6.4	0.1%
Total Lumens:	6,240.7	100%









C	Center Beam fc		Beam Width	
6.0ft	46.7 fc	11.7 ft	5.6 ft	
12.0R	11.7 fc	23.5 ft	11.3 ft	
18.0ft	5.2 fc	35.2 ft	16.9 ft	
24.0ft	2.9 fc	47.0 ft	22.6 ft	
30.0R	1.9 fc	58.7 ft	28.2 ft	