

DAMAR® Installation Instructions

H Track Systems

37631G, 37640G mini joiner

SAFETY INSTRUCTION

- Read all of these instructions before installing the track system.
- Turn off power at main switch before installing or modifying the system.
- Do not install within six inches of any curtain or combustible materials.
- Do not install less than 5 feet above a floor.
- Do not install in damp or wet locations.
- Do not install concealed or extended through building walls.
- Do not attempt to energize anything other than a track light fixture.
- Do not connect a track to more than one branch circuit. Although track light systems may seem to operate acceptably, a dangerous overload of the neutral may occur and result in a risk of fire.
- Check with a qualified electrician before wiring.
- All installation shall be in accordance with NEC and all local codes.
- Save these installation instructions and refer to them when additions or changes to the track configuration are made.

INSTRUCTION STEPS

1. Loosen set screw on end cap and remove from end of track "A" which will receive mini joiner (diagram 1).
2. Repeat step 1 for track "B".
3. Position open ends of tracks in "I" formation as shown in diagram 2.
4. Ensure polarity edges of tracks and connector align. Insert mini joiner into open end of track "A" and tighten positioning screw. Do not force connector into track (diagram 3).
5. Repeat step 4 for track "B".

